

# Test spray RWM 125 for smoke detectors

Seite 1 von 2

---



---

For function tests

Test spray for checking the functionality of optical smoke alarms.

You are not sure whether your smoke alarm is still working reliably? You can check the function of the detector with our ABUS test spray. Simply spray the smoke detector and wait for the warning tone. Optical smoke alarms detect smoke particles in the air. These are simulated realistically by the spray. If there is no alarm at a spray intensity of around five seconds, you should replace the smoke detector.

---

## Technologies

- In case of no alert please repeat test
- Change detector if no alert is given after 5 seconds of testing
- Frei von Schadstoffen aller Art

## Operation and use

- Use for fotoelectronic smoke detectors
- Shake before usage
- Spray 1 - 2 seconds in direction of detector at a distance of approximately 30 cm

## Variants

- Content: 125 ml
-

# Test spray RWM 125 for smoke detectors

Seite 2 von 2

---

## Technical data - Test spray RWM 125 for smoke detectors

Weight	108 g
colour	white
EAN	4003318438684